

Energy performance certificate (EPC)

Unit 16
Mealbank Mill Industrial Estate
Mealbank
KENDAL
LA8 9DL

Energy rating

E

Valid until: **14 May 2028**

Certificate number: **0950-8970-0398-4410-6040**

Property type

B1 Offices and Workshop businesses

Total floor area


531 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy efficiency rating for this property

This property's current energy rating is E.



Properties are also given a score. The larger the number, the more carbon dioxide (CO₂) your property is likely to emit.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

33 | B

If typical of the existing stock

98 | D

Properties are given a rating from A+ (most efficient) to G (least efficient).

Breakdown of this property's energy performance

Main heating fuel

Oil

Building environment

Heating and Mechanical Ventilation

Assessment level

3

Building emission rate (kgCO₂/m² per year)

83.32

Primary energy use (kWh/m² per year)

354

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/9844-4015-0789-0600-4091\)](#).

Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

Assessor contact details

Assessor's name	Kevin Schouten
Telephone	07758519534
Email	kevinschouten.dea@tiscali.co.uk

Accreditation scheme contact details

Accreditation scheme	Stroma Certification Ltd
Assessor ID	STRO001037
Telephone	0330 124 9660
Email	certification@stroma.com

Assessment details

Employer	Tregea Energy
Employer address	Tregea, Bareppa, Budock Water, Falmouth
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	14 May 2018
Date of certificate	15 May 2018
